

MEMORANDUM

Date: November 5, 2013

To: Environmental Health Managers
District Health Directors
Virginia Tech Contract Soil Scientists
Authorized Onsite Soil Evaluators

From: C. Kemper Loyd, P.E., Technical Services Engineer
Office of Environmental Health Services

Subject: Approval of Norwesco and Snyder Industries 750-gallon, 1000-gallon, 1250-gallon, and 1500-gallon Low Profile Septic Tanks for use in Virginia when used with an effluent filter

Approval: The subject tanks do not meet the following *Sewage Handling and Disposal Regulations* (12VAC5-610-815) criteria:

- 48" minimum liquid depth (40" provided)
- 12" minimum freeboard (9" provided)
- 1-2" inlet-to-outlet drop (3" provided)

However, after reviewing the information provided by Norwesco, Inc., and Snyder Industries, the Office of Environmental Health Services approves the tanks for use in Virginia when used with an NSF certified effluent filter.